

Certified Validation Report: Provided by Validator

Audit Information:

Water Supplier Name: **El Segundo** PWS ID: **1910040**
System Type: **Potable** Audit Period: **Calendar 2017**
Utility Representation: **Lucienne Cummings, Anthony Esparza**
Validation Date: **June 6th, 2019** Call Time: **11:00 AM** Sufficient Supporting Documents Provided: **Yes**

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: **67** Data Validity Band (Level): **Band III (51-70)**
ILI: **0.02** Real Loss: **0.27 gallons/connection/day** Apparent Loss: **16.82 gallons/connection/day**
Non-revenue water as percent of cost of operating system: **0.8%**

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator : **Aretha Samuel** Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA